Riverside University HEALTH SYSTEM Medical Center

Activity ID	Bid RFI's
Project:	JOC-BV-01-MECH
Date	3/6/2026
Name:	FDD

RFI #	Date Received	Contractor	Contractor RFI#	RFI Question/Comment	Author	Response
RFI01	2/24/2026	Mesa Energy Systems, Inc.	RFI03	Will you be posting these answers as an addendum to the RFP? If so, when will that be available in order to acknowledge the addendum?	FDD	Yes and March 6, 2026
RFI01	2/23/2026	Mesa Energy Systems, Inc.	RFI02	Please clarify if any of the JOC work will involve the install, service and repair of power boilers, hot water systems, or steam piping? If so, please clarify if the primary bidder will be required to carry a valid C-4 license?	FDD	Yes, the work will include power boilers, hot water systems and steam piping, also you will need to carry a C-4 License.
RFI01	2/23/2026	Mesa Energy Systems, Inc.	RFI01	Please clarify who is responsible for HCAI permitting and inspections? Do the HCAI permitting and inspection fees need to be included in the adjustment factors?	FDD	The Facility (RUHS) will be responsible for HCAI permitting